

CLIENT INFORMATION

Name: Chatham Central School District
SCHOOL/PROJECT INFOR WATER TESTING
BLDG ADDRESS:
CONTACT NAME & NUMBERS: Steve Nieto (518) 392-1525

Legend

- F** Faucet
- DW** Drinking Water
- I** Ice Machine

SAMPLE DATA

Sample Description ID (ID must match container label)

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
MED ELEMENTARY SCHOOL										
1	MED-F-1	Kitchen	Food Prep	x	5:28	0.001				
2	MED-F-2	Kitchen	Food Prep	x	5:27	0.008				
3	MED-F-3	Kitchen	Food Prep	x	5:26	0.014				
4	MED-F-4	Kitchen	Hand Wash Only	x	5:23		0.017			
5	MED-F-5	Kitchen	Hand Wash Only	x	5:24		0.015			
6	MED-F-6	Kitchen	Food Prep	x	5:28	0.007				
7	MED-F-7	Kitchen	Dish Wash Spray	x	5:28	0.002				
8	MED-F-8	Kitchen	Food Prep	x	5:29			0.021		0.003
9	MED-DW-9	Café		x	5:31	0.001				
10	MED-DW-10	room221		x	7:25			0.02		0.007
11	MED-F-11	room221		x	7:25	0.01				0.005
12	MED-DW-12	room212		x	7:21		0.015			0.004
13	MED-F-13	room212		x	7:21		0.016			0.005
14	MED-DW-14	room213		x	7:20	0.005				
15	MED-F-15	room213		x	7:20		0.015			
16	MED-DW-16	room214		x	7:19	0.012				
17	MED-F-17	room214		x	7:19	0.008				
18	MED-DW-18	room215		x	7:10	0.012				
19	MED-F-19	room215	Not Running	x		0.013				
20	MED-F-20	Library		x	5:35			0.032		
21	MED-F-21	Girls Bath/Library		x	5:36	0.003				
22	MED-F-22	Boys Bath/Library		x	5:36	0.003				
23	MED-F-23	Mens/Lobby		x	5:38			0.034		
24	MED-F-24	Mens/Lobby		x	5:38	0.013				
25	MED-F-25	Ladies Bath/Lobby		x	5:40	0.007				
26	MED-F-26	Ladies Bath/Lobby		x	5:40	0.007				
27	MED-DW-27	Lobby Drinking Fountain		x	5:37	0.008				
28	MED-F-28	Custodial		x	5:41	0.01				

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
29	MED-F-29	Room218		x	5:42	0.003				
30	MED-DW-30	Room218		x	5:42	0.003				
31	MED-F-31	Room232		x	5:44	0.004				
32	MED-DW-32	Room232		x	5:44	0.003				
33	MED-DW-33	Room 231		x	5:44	0.002				
34	MED-F-34	Room231		x	5:46	0.003				
35	MED-F-35	Room 219		x	5:46	0.003				
36	MED-DW-36	Room 219		x	5:46	0.003				
37	MED-F-37	Room220		x	5:49	0.008				
38	MED-DW-38	Room220		x	5:49	0.007				
39	MED-F-39	Room230		x	5:48	0.014				
40	MED-F-40	Room229		x	5:52			0.046		0.004
41	MED-DW-41	Hallway/221		x	5:55	0.001				
42	MED-DW-42	Room 221		x	5:54	0.002				
43	MED-F-43	Room221		x	5:54	0.002				
44	MED-F-44	Room221		x	5:53		0.015			
45	MED-DW-45	Room222		x	6:01	0.003				
46	MED-F-46	Room222		x	6:01	0.014				
47	MED-DW-47	Room228		x	6:05	0.002				
48	MED-F-48	Room228		x	6:05	0.005				
49	MED-F-49	room224		x	6:09	0.003				
50	MED-DW-50	room224		x	6:09	0.002				
51	MED-DW-51	Room227		x	6:06	0.003				
52	MED-F-52	Room227		x	6:06	0.004				
53	MED-F-53	Room226		x	6:10	0.005				0.001
54	MED-DW-54	Room226		x	6:10	0.002				
55	MED-F-55	Room225		x	6:11	0.005				
56	MED-DW-56	Room225		x	6:11	0.006				
57	MED-F-57	Supt. Conf. Bath		x	6:14			0.024		
58	MED-F-58	Faculty		x	6:20	0.014				
59	MED-F-59	Faculty		x	6:20	0.006				
60	MED-F-60	Nurse		x	6:16	0.004				
61	MED-F-61	Nurse		x	6:17	0.009				
62	MED-NI-62	Nurse Ice Machine		x	6:17	0.005				
63	MED-DW-63	Hallway/Gym		x	6:25	0.003				
64	MED-F-64	Girls Locker		x	6:24	0.008				
65	MED-F-65	Girls Bath/302		x	6:27		0.018			

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
66	MED-F-66	Girls Bath/302		x	6:27	0.009				
67	MED-F-67	Boys Bath/302		x	6:28		0.016			
68	MED-F-68	Boys Bath/302		x	6:28			0.025		
69	MED-DW-69	Room303		x	6:28	0.011				
70	MED-F-70	Room303		x	6:30	0.013				
71	MED-DW-71	Room317		x	6:31		0.016			0.003
72	MED-F-72	Room317		x	6:31	0.006				0.002
73	MED-F-73	room304		x	6:33	0.008				
74	MED-DW-74	room304		x	6:33	0.009				
75	MED-DW-75	room316		x	6:34	0.007				
76	MED-F-76	room316		x	6:34	0.005				
77	MED-F-77	room305		x	6:39			0.024		
78	MED-DW-78	room305		x	6:40	0.008				
79	MED-F-79	room306		x	6:40	0.008				
80	MED-DW-80	room306		x	6:41	0.014				
81	MED-F-81	room313		x	6:41	0.013				
82	MED-DW-82	room313		x	6:36			0.023		
83	MED-DW-83	Hallway/88 wing		x	6:36	<.001				
84	MED-DW-84	Hallway/88 wing		x	6:38	<.001				
85	MED-F-85	Girls Bath/88 wing		x	6:38	0.013				
86	MED-F-86	Girls Bath/88 wing		x	6:37	0.011				
87	MED-F-87	Boys Bath/88 wing		x	6:37			0.022		
88	MED-F-88	Boys Bath/88 wing		x	6:37	0.01				
89	MED-F-89	room307		x	6:44			0.024		
90	MED-DW-90	room307		x	6:44	0.006				
91	MED-F-91	room312		x	6:43			0.02		
92	MED-DW-92	room312		x	6:43	0.012				
93	MED-DW-93	room311		x	6:48	0.004				
94	MED-F-94	room311		x	6:48	0.002				
95	MED-DW-95	room308		x	6:47	0.005				
96	MED-F-96	room308		x	6:47	0.007				
97	MED-F-97	room310		x	6:50		0.016			0.001
98	MED-DW-98	room310		x	6:50	0.009				
99	MED-DW-99	room309		x	6:49	0.003				
100	MED-F-100	room309		x	6:49		0.017			
101	MED-F-101	room101		x	7:39		0.018			
102	MED-DW-102	room101		x	7:39	0.007				

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
103	MED-F-103	room102		x	7:40	0.011				
104	MED-DW-104	room102		x	7:40	0.001				
105	MED-F-105	room103		x	7:41	0.007				
106	MED-F-106	room103		x						
107	MED-F-107	room104		x	10:03		0.018			
108	MED-F-108	room105		x	7:46		0.016			
109	MED-F-109	room106		x	7:46	0.01				
110	MED-F-110	room107		x	7:47			0.022		0.005
111	MED-F-111	room108		x	7:48		0.015			
112	MED-DW-112	Hallway/downstairs		x	7:43	0.01				
113	MED-F-113	Boys Bath/229		x	5:59	0.009				
114	MED-F-114	Boys Bath/229		x	5:59	0.008				
115	MED-F-115	Boys Bath/229		x	5:59	0.013				
116	MED-F-116	Boys Bath/229		x	5:59			0.05		
117	MED-F-117	Girls Bath/229		x	5:57	0.002				
118	MED-F-118	Girls Bath/229		x	5:57	0.003				
119	MED-F-119	Girls Bath/229		x	5:57	0.002				
120	MED-F-120	Girls Bath/229		x	5:57	0.003				
121	MED-F-121	Main Office Sink		x	6:49	0.004				
122	MED-F-122	310		x	6:44	0.002				
123	MED-F-123	307		x	6:44	0.002				
124	MED-F-124	Downstairs Hall		x	7:42	0.006				
125	N/A									
126	MED-F-126	212-F-Bathroom		x	7:42			0.021		
127	MED-F-127	211-F-Bathroom		x	7:25	0.013				
128	MED-DW-128	223		x	6:03	0.001				
129	MED-F-129	223		x	6:03	0.006				
130	MED-F-130	Art		x	6:57	0.004				
131	MED-F-131	Art		x	7:51		0.015			
132	MED-F-132	215		x	7:10		0.015			
133	MED-F-133	229		x	7:36		0.018			0.004
134	MED-F-134	220		x	7:35	0.006				
135	MED-F-135	220		x		0.003				
139	MED-F-139					0.001				
140	MED-F-140						0.015			

MIDDLE SCHOOL

1	MS-F-1	GA2		x	9:54		0.018			
---	--------	-----	--	---	------	--	-------	--	--	--

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
2	MS-F-2	GA1		x	9:52	0.014				
3	MS-DW-3	GA1		x	9:51	0.008				
4	MS-F-4	GA3		x	9:53	0.012				
5	MS-DW-5	GA3		x	9:52	0.004				
6	MS-DW-6	Hallway/GA6		x	9:55			0.034		
7	MS-F-7	Public Library/conf.		x	10:00	0.006				
8	MS-F-8	Public Library/grd. Floor		x	10:00	0.005				
9	MS-DW-9	Public Library/Lobby		x	10:02	0.003				
10	MS-F-10	GB2		x	10:07	0.006				
11	MS-DW-11	GB2		x	10:07	0.003				
12	MS-F-12	GB1		x	10:09	0.005				
13	MS-DW-13	GB1		x	10:08	0.005				
14	MS-F-14	GB4		x	10:11	0.007				
15	MS-DW-15	GB4		x	10:12	0.006				
16	MS-F-16	GB6		x	10:13	0.005				
17	MS-DW-17	GB6		x	10:13	0.003				
18	MS-F-18	GB8		x	10:15	0.005				
19	MS-DW-19	GB8		x	N/A					
20	MS-F-20	GB5		x	10:16	0.004				
21	MS-DW-21	GB5		x	10:17	0.002				
22	MS-DW-22	Hallway/GB4		x	10:10	0.005				
23	MS-DW-23	Hallway/GB4		x	10:10	0.005				
24	MS-DW-24	Boys Locker		x	10:02			0.020		
25	MS-F-25	Boys Locker		x	10:02			0.056		
26	MS-F-26	Boys Locker		x	10:03	0.006				
27	MS-F-27	Kitchen Bath		x	10:00	0.013				
28	MS-F-28	Kitchen	Food Prep	x	9:53	0.008				
29	MS-F-29	Kitchen	Hand Wash Only	x	9:53			0.021		
30	MS-F-30	Kitchen	Food Prep	x	10:03	0.013				0.001
31	MS-F-31	Kitchen	Food Prep	x	9:54		0.016			0.001
32	MS-I-32	Kitchen Ice Machine		x	9:58	<0.001				
33	MS-F-33	Band Office		x	9:51	0.012				
34	MS-F-34	Boys Bath/Gym		x	9:56		0.015			0.005
35	MS-F-35	Boys Bath/Gym		x	9:50			0.028		0.008
36	MS-F-36	Girls Bath/Gym		x	9:49			0.020		0.006
37	MS-F-37	Girls Bath/Gym		x	9:49			0.024		0.007
38	MS-F-38	Custodial Office		x	10:40	0.012				

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
39	MS-DW-39	Custodial Office		x	10:40	0.007				
40	MS-DW-40	Hallway/Gym		x	9:48	0.003				
41	MS-F-41	Bathroom/Library		x	10:05	0.011				
42	MS-F-42	Copy/Library		x	10:04	0.002				
43	MS-F-43	1A1		x	10:21		0.016			
44	MS-F-44	1A1		x	10:22			0.025		
45	MS-F-45	1B1		x	N/A					
46	MS-F-46	1B2		x	10:32	0.012				
47	MS-F-47	1B2		x	10:33	0.012				
48	MS-F-48	1B2		x	10:33			0.028		
49	MS-F-49	1B2		x	10:34			0.024		
50	MS-F-50	1B2		x	10:34			0.034		
51	MS-F-51	1B4		x	N/A					
52	MS-F-52	1B4		x	N/A					
53	MS-F-53	1B6		x	N/A					
54	MS-F-54	1B8		x	10:39			0.14		
55	MS-F-55	1B8		x	10:39			0.033		
56	MS-F-56	1B8		x	10:38			0.021		
57	MS-F-57	1B8		x	10:38			0.05		
58	MS-F-58	1B8		x	10:38	0.008				
59	MS-DW-59	Hallway/1B4		x	10:35		0.017			0.004
60	MS-DW-60	Hallway/1B4		x	10:35			0.02		0.009
61	MS-F-61	Main Office		x	10:08	0.006				
62	MS-F-62	1C1		x	10:13		0.015			0.012
63	MS-F-63	1C7 Nurse		x	10:09		0.013			
64	MS-F-64	1C7 Nurse		x	10:09	0.008				
65	MS-NI-65	1C7 Nurse		x	10:11	>0.001				
66	MS-DW-66	Hallway/1C7		x	10:12	0.004				
67	MS-DW-67	Hallway/1C7		x	10:12	0.004				
68	MS-DW-68	Girls Locker		x	N/A					
69	MS-F-69	Girls Locker		x	10:05			0.048		0.012
70	MS-F-70	Girls Locker		x	10:05	0.009				
71	MS-I-71	Girls Locker		x	10:05			0.034		
72	MS-F-72	Faculty		x	10:30	0.002				
73	MS-F-73	2A2		x	10:28	0.013				
74	MS-DW-74	2A2		x	10:29	0.006				
75	MS-F-75	2A1		x	10:26			0.027		0.007

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
76	MS-F-76	2A1		x	10:27			0.027		0.007
77	MS-F-77	2A1		x	10:27	0.006				
78	MS-F-78	2A1		x	10:29	0.008				
79	MS-F-79	Mens/Faculty		x	10:30			0.075		0.012
80	MS-F-80	Womens/Faculty		x	10:31	0.012				
81	MS-F-81	2B2		x	10:31			0.065		
82	MS-F-82	2B2		x	10:31			0.14	1.5	
83	MS-F-83	2B2		x	10:32			0.038		
84	MS-F-84	2B2		x	10:32			0.053		
85	MS-F-85	2B2		x	10:32			0.030		
86	MS-F-86	2B2		x	10:32			0.058		
87	MS-F-87	2B2		x	10:33			0.034		
88	MS-F-88	2B2		x	10:33			0.048		
89	MS-F-89	2B2		x	10:33			0.024		
90	MS-F-90	2B2		x	10:33			0.045		
91	MS-F-91	2B2		x	10:35			0.029		
92	MS-F-92	2B2		x	10:35			0.064		
93	MS-F-93	2B4		x	N/A					
94	MS-F-94	2B3		x	N/A					
95	MS-DW-95	hallway/2B4		x	10:30	0.002				
96	MS-DW-96	hallway/2B4		x	10:30	0.003				
97	MS-F-97	2B8		x	10:24			0.046		
98	MS-F-98	2B8		x	10:24			0.048		
99	MS-F-99	2B8		x	10:25			0.086		
100	MS-F-100	2B8		x	10:25			0.053		
101	MS-F-101	2B8		x	10:28			0.042		
102	MS-F-102	2B8		x	10:28			0.041		
103	MS-F-103	2B8		x	10:26			0.066		
104	MS-F-104	2B8		x	10:26			0.056		
105	MS-F-105	2C3		x	10:17			0.087	4.81	
106	MS-F-106	2C3		x	10:17			0.12	8.14	
107	MS-F-107	2C3		x	10:17			0.04	1.95	
108	MS-F-108	2C3		x	10:17			0.041	1.65	
109	MS-F-109	2C3		x	10:18			0.021		
110	MS-F-110	2C3		x	10:18			0.11		
111	MS-F-111	2C3		x	10:18			0.04	2.78	
112	MS-F-112	2C3		x	10:18			0.084	2.34	

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
113	MS-F-113	2C3		x	10:20			0.052		
114	MS-F-114	2C3		x	10:20			0.15	3.84	
115	MS-F-115	2C3		x	10:20			0.04	1.40	0.007/Lead
116	MS-F-116	2C3		x	10:20			0.25	1.35	
117	MS-F-117	2C3		x	10:21			0.06		
118	MS-F-118	2C6		x	10:15	0.010				
119	MS-DW-119	Hallway/2C4		x	10:22	0.009				
120	MS-DW-120	Hallway/2C4		x	10:22		0.015			0.001
121	MS-F-1C7	Nurse Bath		x	10:10	0.004				
122	MS-F-122	Kitchen Pedal	Removed	x	9:55			0.05	1.56	
123	MS-F-123	Art		x	10:23	0.006				
124	MS-F-124	Art		x	10:23	0.009				
125	MS-F-125	Art		x	10:23	0.008				
126	MS-F-126	Art		x	10:24	0.01				
127	MS-F-127	Art		x	10:24	0.007				
128	MS-F-128	Art		x	10:25	0.006				
129	MS-F-129	2B2-F		x	10:37			0.079	2.3	
130	MS-F-130	Kitchen	Food Prep	*		0.001				
HIGH SCHOOL										
1	HS-F-1	room 120		x	8:12			0.027		
2	HS-F-2	room 120		x	8:13			0.021		
3	HS-F-3	room 121		x	8:17			0.039		
4	HS-F-4	room121		x	8:17			0.045		
5	HS-F-5	room121		x	8:18	0.010				
6	HS-F-6	room121		x	8:19	0.006				
7	HS-F-7	room121		x	8:19	0.012				
8	HS-F-8	room121		x	8:19	0.009				
9	HS-F-9	room121		x	8:20	0.003				
10	HS-F-10	room122		x	8:22			0.26		
11	HS-F-11	room122		x	8:23		0.017			
12	HS-F-12	room122		x	8:24		0.018			
13	HS-F-13	room123		x	8:29			0.073		
14	HS-F-14	room123		x	8:28			0.061		
15	HS-F-15	room123		x	8:28			0.032		
16	HS-F-16	124A		x	8:34			0.067		
17	HS-F-17	room125		x	8:39	0.005				
18	HS-F-18	room125		x	8:38			0.021		

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
19	HS-F-19	room125		x	8:38			0.043		
20	HS-F-20	room126		x	8:41			0.037		
21	HS-F-21	room126		x	8:41		0.017			
22	HS-F-22	room126		x	8:42			0.026		
23	HS-F-23	room126		x	8:42		0.019			
24	HS-F-24	room126		x	8:42			0.02		
25	HS-F-25	room 126		x	8:43	0.014				
26	HS-F-26	room 126		x	8:44			0.034		
27	HS-F-27	room 126		x	8:44			0.021		
28	HS-F-28	room126		x	8:45			0.03		
29	HS-F-29	room126		x	8:45		0.016			
30	HS-F-30	room126		x	8:45			0.032		0.007
31	HS-F-31	room126		x	8:46			0.022		0.01
32	N/A									
33	HS-F-33	room126A		x	8:47			0.074		
34	HS-F-34	room127		x	8:51			0.022		
35	HS-F-35	room127		x	8:52			0.024		
36	HS-F-36	room127		x	8:52			0.046		
37	HS-F-37	room127		x	8:53			0.060		
38	HS-F-38	Boys Bath/128		x	8:49			0.021		
39	HS-F-39	Boys Bath/128		x	8:49		0.016			
40	HS-F-40	Girls Bath/128		x	8:50		0.017			
41	HS-F-41	Girls Bath/128		x	8:50			0.027		
42	HS-F-42	Girls Bath/128		x	8:50			0.032		0.002
43	HS-DW-43	Hallway128/water fountain		x	8:48	0.007				
44	N/A			x						
45	HS-DW-45	Hallway cust./water fountain		x	8:16			0.043		0.001
46	HS-DW-46	Hallway cust./water fountain		x	8:16			0.066		0.014
47	HS-DW-47	Custodian Drinking Fountain		x	8:15	0.002				
48	HS-F-48	Custodian Room		x	8:15	0.012				
49	HS-F-49	Kitchen	Food Prep	x	8:40			0.024		0.001
50	HS-F-50	Kitchen	Food Prep	x	8:40			0.024		0.002
51	HS-F-51	Kitchen	Food Prep	x	8:40		0.018			0.001
52	HS-F-52	Kitchen	Hand Wash Only	x	8:39			0.025		
53	HS-F-53	Kitchen	Hand Wash Only	x	8:39			0.031		
54	HS-F-54	Faculty		x	8:42	0.002				
55	HS-F-55	room107		x	8:35			0.052		0.01

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
56	HS-F-56	room107		x	8:35			0.023		0.007
57	HS-F-57	room107		x	8:35			0.034		0.009
58	HS-F-58	room105		x	8:34			0.038		
59	HS-F-59	Boys Bath/104		x	8:33			0.036		0.01
60	HS-F-60	Boys Bath/104		x	8:33	0.008				
61	HS-F-61	Boys Bath/104		x	8:33	0.009				
62	HS-F-62	Girls Bath/104		x	8:31	0.013				
63	HS-F-63	Girls Bath/104		x	8:31	0.009				
64	HS-F-64	Girls Bath/104		x	8:31	0.009				
65	HS-DW-65	Hallway 104		x	8:30	0.009				
66	HS-DW-66	Hallway 104		x	8:30	0.004				
67	HS-F-67	Library		x	8:30			0.045		
68	HS-F-68	Library		x	8:29			0.08		
69	HS-F-69	Main Office		x	8:27			0.026		
70	HS-F-70	Mens Bath Lobby		x	8:24	0.008				
71	HS-F-71	Womens Bath Lobby		x	8:24	0.005				
72	HS-DW-72	Lobby		x	8:24	<0.001				
73	HS-F-73	Nurse		x	8:22		0.015			
74	HS-F-74	Nurse		x	8:22	0.009				
75	HS-F-75	Boys Bath/Gym Hall		x	8:23	0.005				
76	HS-F-76	Girls Bath/Gym Hall		x	8:18	0.006				
77	HS-DW-77	Gym Hall		x	8:19	<0.001				
78	HS-DW-78	Gym Hall		x	8:19	<0.001				
79	HS-I-79	Mech. Room/Ice Machine		x	8:21	0.012				
80	HS-F-80	Girls Locker		x	8:18	0.002				
81	HS-DW-81	Girls Locker		x	8:17			0.058		
82	HS-F-82	Boys Locker		x	8:16	0.011				
83	HS-DW-83	Boys Locker		x	8:16			0.026		0.008
84	HS-F-84	Room124		x	8:32			0.034		
85	HS-F-85	Room124		x	8:32			0.024		
86	HS-F-86	Room124		x	8:32			0.02		
87	HS-F-87	Room124		x	8:33		0.018			
88	HS-F-88	Room 107		x	8:35			0.028		0.005
89	HS-F-89	Room 121		x	8:20	0.014				
90	HS-F-90	Room 123		x	8:26			0.029		
91	HS-F-91	Room 123		x	8:27			0.028		
92	HS-F-92	Room 124		x	8:31			0.028		0.012

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ <.014	Lead @ .015-.019	Lead @ >.020	Copper	Retest after Remediation
93	HS-F-93	Room 124A		x	8:34			0.16		
94	HS-F-94	Room 125		x	8:36			0.037		
95	HS-F-95	Room 125		x	8:37			0.032		
96	HS-F-96	Band Room		x	8:14			0.023		
97	HS-F-97	Dishwasher		x	8:37	0.005				
98	HS-F-98	Mens Fac		x	8:42		0.014			
99	HS-F-99	Womens Fac		x	8:43		0.017			
100	HS-F-100	Main Office		x	8:27			0.027		
101	HS-F-101	Room 123A		x	8:58			0.053		

BUS GARAGE

1	BG-F-1	Al's Bathroom		x	5:15	0.005				
2	BG-F-2	Womens/Breakroom		x	5:13		0.015			
3	BG-F-3	Mens/Breakroom		x	5:12	0.014				
4	BG-F-4	Breakroom		x	5:11	0.009				
5	BG-DW-5	Breakroom		x	5:10	0.006				
6	BG-F-6	Maint./Bathroom		x	5:08	0.013				
7	BG-F-7	Maint./Shop		x	5:07	0.008				
8	BG-DW-8	Maint./Shop		x	5:06		0.015			